



**LEVEL 5-FIRE PROTECTION PLAN-CONFERENCE CENTER
PIPING PLAN**

1/8" = 1'-0"

LEGEND: RATED WALLS

---	SMOKE GUARD BARRIER	---	NO RISE FIRE PARTITION (PER NFPA 706 FLOOR-TO-U/S OF SLAB)
---	HABITABLE FLOOR FIRE BARRIER (PER NFPA 706 FLOOR-TO-U/S OF SLAB)	---	ONE HOUR FIRE PARTITION (PER NFPA 706 FLOOR-TO-U/S OF SLAB)
---	NO RISE FIRE BARRIER WALL (PER NFPA 706 FLOOR-TO-U/S OF SLAB)	---	SMOKE BARRIER PARTITION WALL (PER NFPA 706 FLOOR-TO-U/S OF SLAB)
---	NO RISE FIRE BARRIER (PER NFPA 706 FLOOR-TO-U/S OF SLAB)	---	HORIZONTAL EXIST. PASSAGEWAY

SNA	MAKE	MODEL	SNA NO.	SIZE	FINISH	TEMP.	TYPE	ESQUICHON	QUANT.
○	Viking	MICROFAST QUICK RESPONSE	VK-300	1/2"	CHROME	155°	PENDENT	5.60	RECESSED/CHROME
●	Viking	HORIZON MIRAGE Q.R. CONCEAL	VK-404	1/2"	BRASS	155°	PENDENT	5.60	CONCEALER/WHITE
●	Viking	QUICK RESPONSE DRY PENDENT	VK-176	1/2"	BRASS	155°	PENDENT	5.60	RECESSED/CHROME
○	Viking	MICROFAST QUICK RESPONSE	VK-300	1/2"	BRASS	155°	UPRIGHT	5.60	RECESSED/CHROME
▷	Viking	DRY SIDEWALL	VK	1/2"	CHROME	155°	SIDE WALL	5.60	RECESSED/CHROME

This drawing and the information hereon is the property of ABL Fire Protection, LLC and may not be reproduced, altered or used in any form without consent from ABL Fire Protection, LLC

CONTRACTOR:

 Arthur K. Lamson, Jr., N.I.C.E.T. Level III #20462 FS
 I certify that to the best of my knowledge this plan, prepared under my supervision, is in accordance with applicable NFPA standards, current building codes.

PROJECT:
 LEVEL 5-FIRE PROTECTION FLOOR PLAN
 CONFERENCE CENTER
 PLANNING OF THE ADMINISTRATION
 UPPER FLOOR ADMINISTRATION
 Ref: A-1805, 1-1805, S-GP,
 P1055

REVISION:
 4501 Creedmoor Road
 Raleigh, North Carolina

DATE: 12-3-2007
SCALE: 1/8" = 1'-0"
SHEET #: P199C

