

... Fire Protection by Computer Design

ABL FIRE PROTECTION  
RALEIGH, NORTH CAROLINA

Job Name : SOLEIL HIGH ZONE STANDPIPE  
Building :  
Location : RALEIGH, NORTH CAROLINA  
System : HIGH STANDPIP  
Contract :  
Data File : SOLEIL 260 PUMP STANDPIPE.WXF

HYDRAULIC DESIGN INFORMATION SHEET

Name - SOLEIL CENTER  
Location - RALEIGH, NORTH CAROLINA  
Building -  
Contractor -  
Calculated By - JSB  
Occupancy - RESIDENTIAL

Date - 11-25-07

System No. - HIGH STANDPIP  
Contract No. -  
Drawing No. - FP-5

S (X)NFPA 14 Number of Standpipes ( )1 (X)2 ( )3 ( )4 ( )  
Y ( )Other  
S ( )Specific Ruling Made by Date

|   |                                   |                     |      |                 |
|---|-----------------------------------|---------------------|------|-----------------|
| E | Flow at Top Most Outlet           | - 500               | Gpm  | System Type     |
| M | Pres. at Top Most Outlet          | - 125               | Psi  | (X) Wet ( ) Dry |
|   | Flow For Ea. Additional Standpipe | - 250               | Gpm  |                 |
| D | Total Additional Flow             | - 250               | Gpm  |                 |
| E | Elevation at Highest Outlet       | - 433               | Feet |                 |
| S | Hose Valve Connection             | ( )1 1/2" (X)2 1/2" |      |                 |
| I | Class Service                     | ( )I ( )II (X)III   |      |                 |
| G | Note:                             |                     |      |                 |
| N |                                   |                     |      |                 |

|             |                  |                      |                   |
|-------------|------------------|----------------------|-------------------|
| Calculation | Gpm Required 750 | Psi Required 315.653 | AT PUMP DISCHARGE |
| Summary     | C-Factor Used:   | Overhead 120         | Underground 140   |

|   |                     |                |                    |
|---|---------------------|----------------|--------------------|
| W | Water Flow Test:    | Pump Data:     | Tank or Reservoir: |
| A | Date of Test -      |                | Cap.               |
| T | Time of Test -      | Rated Cap. 750 | Elev.              |
| E | Static (Psi) - 106  | @ Psi 260      |                    |
| R | Residual (Psi) - 92 | Elev. 24.5     | Well               |
|   | Flow (Gpm) - 1470   |                | Proof Flow Gpm     |
| S | Elevation - 0       |                |                    |


U  
P Location:  
P  
L Source of Information:  
Y

# Water Supply Curve (C)

ABL FIRE PROTECTION  
SOLEIL HIGH ZONE STANDPIPE

Page 2  
Date 9-14-107

|   |   |  |
|---|---|--|
| <b>City Water Supply:</b><br>C1 - Static Pressure : 106<br>C2 - Residual Pressure: 92<br>C2 - Residual Flow : 1470<br><br><b>City Water Adjusted to Pump Inlet for Pf - Elev - Hose Flow</b><br>A1 - Adjusted Static: 76.096<br>A2 - Adj Resid : 65.835 @ 750<br>A3 - Adj Resid : 53.864 @ 1125 | <b>Pump Data:</b><br>P1 - Pump Churn Pressure : 286<br>P2 - Pump Rated Pressure : 260<br>P2 - Pump Rated Flow : 750<br>P3 - Pump Pressure @ Max Flow : 169<br>P3 - Pump Max Flow : 1125<br>City Residual Flow @ 0 = 4390.85<br>City Residual Flow @ 20 = 3921.60<br>City Water @ 150% of Pump = 97.46 | <b>Demand:</b><br>D1 - Elevation : 186.666<br>D2 - System Flow :<br>D2 - System Pressure : 315.653<br>Hose ( Adj City ) : 720<br>Hose ( Demand ) : 750<br>D3 - System Demand : 750<br>Safety Margin : 10.182 |
|---|---|--|



# Fittings Used Summary

ABL FIRE PROTECTION  
SOLEIL HIGH ZONE STANDPIPE

Page 3  
Date 9-14-107

| Fitting Legend |                           |  |   |     |     |    |     |      |    |     |     |     |    |     |     |    |    |    |    |     |     |
|----------------|---------------------------|--|---|-----|-----|----|-----|------|----|-----|-----|-----|----|-----|-----|----|----|----|----|-----|-----|
| Abbrev.        | Name                      | ½  | ¾ | 1   | 1¼  | 1½ | 2   | 2½   | 3  | 3½  | 4   | 5   | 6  | 8   | 10  | 12 | 14 | 16 | 18 | 20  | 24  |
| B              | Generic Butterfly Valve   | 0  | 0 | 0   | 0   | 0  | 0   | 7    | 10 | 0   | 12  | 9   | 10 | 12  | 19  | 21 | 0  | 0  | 0  | 0   | 0   |
| E              | 90' Standard Elbow        | 2  | 2 | 2   | 3   | 4  | 5   | 6    | 7  | 8   | 10  | 12  | 14 | 18  | 22  | 27 | 35 | 40 | 45 | 50  | 61  |
| F              | 45' Elbow                 | 1  | 1 | 1   | 1   | 2  | 2   | 3    | 3  | 3   | 4   | 5   | 7  | 9   | 11  | 13 | 17 | 19 | 21 | 24  | 28  |
| G              | Generic Gate Valve        | 0  | 0 | 0   | 0   | 0  | 1   | 1    | 1  | 1   | 2   | 2   | 3  | 4   | 5   | 6  | 7  | 8  | 10 | 11  | 13  |
| H              | 45' Grvd-Vic Elbow #11    | 0  | 0 | 1   | 1.5 | 2  | 2   | 3    | 3  | 3.5 | 3.5 | 4.5 | 5  | 6.5 | 8.5 | 10 | 18 | 20 | 23 | 25  | 30  |
| I              | 90' Grvd-Vic Elbow #10    | 0  | 0 | 2   | 3   | 4  | 3.5 | 6    | 5  | 8   | 7   | 8.5 | 10 | 13  | 17  | 20 | 23 | 25 | 33 | 36  | 40  |
| J              | 90'Tee-Branch Grv Vic #20 | 0  | 0 | 4.5 | 6   | 8  | 8.5 | 10.8 | 13 | 17  | 16  | 21  | 25 | 33  | 41  | 50 | 65 | 78 | 88 | 98  | 120 |
| S              | Generic Swing Check Valve | 4  | 5 | 5   | 7   | 9  | 11  | 14   | 16 | 19  | 22  | 27  | 32 | 45  | 55  | 65 | 76 | 87 | 98 | 109 | 130 |
| T              | 90' Flow thru Tee         | 3  | 4 | 5   | 6   | 8  | 10  | 12   | 15 | 17  | 20  | 25  | 30 | 35  | 50  | 60 | 71 | 81 | 91 | 101 | 121 |
| Zaf            | Ames 3000SS               | Fitting generates a Fixed Loss Based on Flow |   |     |     |    |     |      |    |     |     |     |    |     |     |    |    |    |    |     |     |
| Zai            | Ames 4000SS               | Fitting generates a Fixed Loss Based on Flow |   |     |     |    |     |      |    |     |     |     |    |     |     |    |    |    |    |     |     |

Pressure / Flow Summary - STANDARD

ABL FIRE PROTECTION  
SOLEIL HIGH ZONE STANDPIPE

Page 4  
Date 9-14-107

| Node No. | Elevation | K-Fact | Pt Actual | Pn | Flow Actual | Density | Area | Press Req. |
|----------|-----------|--------|-----------|----|-------------|---------|------|------------|
| STD1     | 432.0     |        | 125.0     | na | 500.0       |         |      |            |
| STD2     | 432.0     |        | 128.21    | na | 250.0       |         |      |            |
| HZT      | 24.5      |        | 305.93    | na |             |         |      |            |
| CON      | 17.5      |        | 309.8     | na |             |         |      |            |
| HZD      | 24.5      |        | 315.65    | na |             |         |      |            |
| HZS      | 24.5      |        | 65.83     | na |             |         |      |            |
| RED      | 17.5      |        | 69.67     | na |             |         |      |            |
| MF4      | 3.0       |        | 76.23     | na |             |         |      |            |
| DI       | 1.0       |        | 87.2      | na |             |         |      |            |
| HDI      | -3.0      |        | 89.39     | na |             |         |      |            |
| HD2      | -3.0      |        | 90.03     | na | 720.0       |         |      |            |
| POC      | 1.0       |        | 92.0      | na |             |         |      |            |

The maximum velocity is 7.58 and it occurs in the pipe between nodes HZT and CON

| Hyd. Ref. Point          | Qa<br>Qt         | Dia. "C"<br>Pf/Ft      | Fitting<br>or<br>Eqv. Ln.                     | Pipe<br>Ftng's<br>Total       | Pt<br>Pe<br>Pf              | Pt<br>Pv<br>Pn | *****<br>Notes<br>*****                       |
|--------------------------|------------------|------------------------|---|-------------------------------|-----------------------------|----------------|---|
| STD1 to HZT              | 500.00<br>500.0  | 6.357<br>120<br>0.0078 | 5I 62.867<br>1B 12.573<br>0.0                 | 497.000<br>75.440<br>572.440  | 125.000<br>176.488<br>4.443 |                | Qa = 500<br>Vel = 5.05                        |
|                          | 0.0<br>500.00    |                        |   |                               |                             | 305.931        | K Factor = 28.59                              |
| STD2 to HZT              | 250.00<br>250.0  | 6.357<br>120<br>0.0022 | 5I 62.867<br>1B 12.573<br>0.0                 | 497.000<br>75.440<br>572.440  | 128.210<br>176.488<br>1.233 |                | Qa = 250<br>Vel = 2.53                        |
| HZT to CON               | 500.00<br>750.0  | 6.357<br>120<br>0.0164 | 1J 31.433<br>1B 12.573<br>0.0                 | 7.000<br>44.006<br>51.006     | 305.931<br>3.032<br>0.838   |                | Vel = 7.58                                    |
| CON to HZD               | 0.0<br>750.0     | 6.357<br>120<br>0.0164 | 1S 40.235<br>1B 12.573<br>0.0                 | 1.000<br>52.808<br>53.808     | 309.801<br>4.968<br>0.884   |                | * Fixed loss = 8<br>Vel = 7.58                |
|                          | 0.0<br>750.00    |                        |   |                               |                             | 315.653        | K Factor = 42.21                              |
| System Demand Pressure   |                  |                        |   |                               |                             | 315.653        |   |
| Safety Margin            |                  |                        |   |                               |                             | 10.182         |   |
| Continuation Pressure    |                  |                        |   |                               |                             | 325.835        |   |
| Pressure @ Pump Outlet   |                  |                        |   |                               |                             | 325.835        |   |
| Pressure From Pump Curve |                  |                        |   |                               |                             | -260.000       |   |
| Pressure @ Pump Inlet    |                  |                        |   |                               |                             | 65.835         |   |
| HZS to RED               | 0.0<br>750.0     | 6.357<br>120<br>0.0164 | 1I 12.573<br>1G 3.772<br>1J 31.433            | 1.000<br>47.778<br>48.778     | 65.835<br>3.032<br>0.801    |                | Vel = 7.58                                    |
| RED to MF4               | 0.0<br>750.0     | 8.249<br>120<br>0.0046 | 1B 14.094<br>1J 38.759<br>0.0                 | 8.500<br>52.853<br>61.353     | 69.668<br>6.280<br>0.284    |                | Vel = 4.50                                    |
| MF4 to DI                | 0.0<br>750.0     | 8.249<br>120<br>0.0046 | 1Zai 0.0<br>1E 21.141<br>0.0                  | 1.000<br>21.141<br>22.141     | 76.232<br>10.866<br>0.102   |                | * Fixed loss = 10<br>Vel = 4.50               |
| DI to HDI                | 0.0<br>750.0     | 8.27<br>140<br>0.0034  | 1H 10.28<br>1G 6.326<br>1J 52.191<br>1I 20.56 | 45.000<br>89.357<br>134.357   | 87.200<br>1.732<br>0.462    |                | Vel = 4.48                                    |
| HDI to HD2               | 0.0<br>750.0     | 10.28<br>140<br>0.0012 | 2F 33.148<br>1T 75.336<br>1G 7.534            | 420.000<br>116.018<br>536.018 | 89.394<br>0.0<br>0.637      |                | Vel = 2.90                                    |
| HD2 to POC               | 720.00<br>1470.0 | 10.28<br>140<br>0.0041 | 1F 16.574<br>2G 15.067<br>1Zaf 0.0            | 131.000<br>31.641<br>162.641  | 90.031<br>1.298<br>0.671    |                | Qa = 720<br>* Fixed loss = 3.03<br>Vel = 5.68 |
|                          | 0.0              |                        |   |                               |                             |                |   |

Final Calculations - Standard

ABL FIRE PROTECTION  
SOLEIL HIGH ZONE STANDPIPE

Page 6  
Date 9-14-107

---

| Hyd.<br>Ref.<br>Point | Qa<br><br>Qt | Dia.<br>"C"<br>Pf/Ft | Fitting<br>or<br>Eqv. Ln. | Pipe<br>Ftng's<br>Total | Pt<br>Pe<br>Pf | Pt<br>Pv<br>Pn | *****             | Notes | ***** |
|-----------------------|--------------|----------------------|---------------------------|-------------------------|----------------|----------------|-------------------|-------|-------|
| 1470.00               |              |                      |                           |                         | 92.000         |                | K Factor = 153.26 |       |       |

---